

# Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Armorthane USA Inc  
2660 N. Eastgate Ave  
Springfield, MO 65803

**Plant Location:**

Santa Fe Springs, CA

**Standards:**

NSF/ANSI 61 Section 5 (2007a)

**Certificate Expires:**

12/31/2013

**Material/Product:**


Polyurethane Barrier Material

**Contact Temperature:**

23 ± 2° C

**Models:**

Aquasafe



THIS CERTIFICATION MARK MAY BE  
APPLIED TO THE APPROVED PRODUCTS  
AND TO THEIR PACKAGING OR  
DESCRIPTIVE LITERATURE



ANSI Accredited Program  
PRODUCT CERTIFICATION  
ID #0303

See attached sheet for any additional information and restrictions

## ADDITIONAL INFORMATION

### COMPANY

Contact  
Phone

Amorthane USA Inc  
2660 N. Eastgate Ave  
Springfield, MO 65803  
Technical Department  
417-831-5090

### PRODUCT DESCRIPTION

Product Brand Name/Model Number

Polyurethane Barrier Material  
Aquasafe

### MATERIAL CHARACTERISTIC

Minimum tank size (gallons)  
Max Surface Area/Vol ratio (sq cm/L)

500  
48

Colors

Number of coats <sup>(1)</sup>

1

Dry film thickness (mils) <sup>(1)</sup>

175

Recoat dry time/temperature

Total cure time/temperature

48 hrs @ 25 C

Mix Ratio

Please refer to manufacturer's  
Instruction

Flushing or preparation instruction  
prior to use

Flush with adequate amount of  
water. Please refer to manufacturer's  
instruction.

Comments

Please refer to manufacturer's  
Instruction.

### CONTACT RESTRICTION

Contact Temperature (°C)  
Contact Material

23 ± 2  
Water

Note (1) As tested.